

Opinion

Registration number SMH-H / EH 29/2006

Commission number Application date File number
8102000312 21 March 2006 EH 29/2006

Name and address of the certificate holder D + H Mechatronic
Georg-Sasse-Str. 28-32
22949 Ammersbek
Germany

Test item: Lift shaft smoke exhaust
Lift Smoke Control LSC

Test location: Georg-Sasse-Str. 28-32
22949 Ammersbek,
Germany

Date of issue: 29 March 2006

Test fundamentals: Declaration of Conformity, Operating Instructions,
relevant DIN VDE regulations, Lifts Directive 95/16/EC,
German federal state building regulations

Result of test: The LSC system is not an immediate part of the lift
installation, but in our view can be regarded as a device
required for operating lifts. Hence it does not constitute
equipment unconnected with lifts, particularly as
building regulations require smoke detection in lift
shafts.
However, as the LSC system does not provide any
uncloseable opening to the open air, contrary to the
requirements of the federal state building regulations,
the consent of the appropriate building planning
authorities must be obtained before the system is
installed.

Hanover -
Date: 29 March 2006

Technical experts:



Dipl.-Ing Rosin Dipl.-Ing Kunze